



WATER BOARD

HEAD OFFICE : Corner Pitt and Bathurst Streets, Sydney, N.S.W
Postal Address : P.O. Box A53, Sydney South, N.S.W 2000 DX14 Telex 127881 Telephone: 562 6238

CERTIFICATE OF AUTHORISATION
(Valid Only Within the Board's Area of Operations)

File No. 341889F7

Authorisation Number

94/00009

Description of Submission

Dry-Treat 100N penetrating sealer for waterproofing concrete structures, composition isobutylmethacrylate, free of solvents, colourless neutral liquid, Application:- low pressure spray equipment. **AUTHORISED FOR USE IN CONTACT WITH POTABLE WATER.**

Special Conditions

1. The Board accepts no responsibility for the function, operation, performance, or the efficiency of the product.
2. There must be no change in the source, nature and origin of the materials or in the manufacturing process or location.
3. The product must be used in accordance with the manufacturer's instructions.
4. This Certificate is granted until 16th September 1995. At the end of this time the product is required to demonstrate compliance with AS4020.
5. No claim shall be made through advertising, promotion or in any other way that the product has been authorised or tested by the Board other than in the specified terms of the authorisation.

Issued To

Dry-Treat (Australia) Pty Ltd
Suite 703, 37 Pitt Street
Sydney NSW 2000

Manufacturer's Name

Signed Drawing Issued Nil

Tested To AS 4020 (INT) 1992

Evaluation Report Issued EWS 4007/92.97 -07/01/94

PROJECT MANAGER
Standards and Authorisation

1 MAR 1994

This Certificate is issued in accordance with the Board's Act and By-Laws and authorises the items described above to be connected to the Board's water supply and/or sewerage systems. This Certificate is issued without alteration or erasure.